



ROC L-16 092461

FIRE EQUIPMENT SALES
AND SERVICE CORPORATION

ROC L-67 092462

3107 W. VIRGINIA AVE. ★ PHX, AZ 85009-1804 ★ (602) 433-2484 ★ Fax (602) 433-9626
2921 S. KISH AVE ★ YUMA, AZ 85365 ★ (928) 341-0025 ★ Fax (928) 341-0356
SHOW LOW ★ PINETOP ★ LAKESIDE ★ (928) 632-2292

11/1/2012

Jeff Akins
Blue Ridge Elementary
1200 W. Mountain Blvd.
Lake Side, Az. 85929

Phone: 928-369-3945
E-Mail: jakins@brusdk12.az.us
DNR#: SLM182

RE: Fire hydrant repairs per system report dated 7-26-2012. Elementary School East.

American Fire Equipment Sales & Service would like to present you with the following proposal for the above referenced facility.

Deficiencies Noted

- Fire hydrant leaks from unerground when hydrant is fully opened.

Scope of Work

- Valve rebuild kit for leaking weep holes on fire hydarant.

Cost Summary

American Fire Equipment is pleased to provide and complete the above scope of work for the sum of:

Total Labor	\$680.00
Total Materials	\$220.00
Sub Total	\$900.00
Tax	\$20.46
Total Proposal	<u>\$920.46</u>

Exclusions

Plans, permits and or city fees, engineering, bonds, freight, shipping, sales tax, OCIP's, patching, paint, fire stopping, fire watch, panel programming, and re-acceptance testing, additional repair material, equipment or labor that is not specified in this proposal. Billing programs, special reporting systems, or any additional insurance beyond our standard coverage.

Bid is valid for work to be done during normal business hours (Monday-Friday between 7:00 am and 4:00 pm), with the repair scheduled at your convenience. No additional work scope will be completed without the prior approval of the Owner. All work shall be conducted per NFPA applicable standards, Local Fire Code(s) and manufacturer instructions. Proposal valid for 60 Days, Net 30 on all invoices upon approved credit.